



Addendum No. 2

To: **All Contractors**
Date: March 10, 2022
Re: **Lincoln County Ambulance District**
Administration & Base Station 1 Renovation & Addition
1392 S. Third
Troy, Missouri 63379

The following Drawing and/or Project Manual Specification clarifications, additions or alterations modify and supersede previously issued documents in reference to the above project. Acknowledge receipt of this Addendum on your Bid Form.

IMPORTANT: This addendum and all bidding construction documents represent a comprehensive scope of work. It is each contractor's responsibility to reference all drawings, specifications and addendums to verify their respective scope of work.

CLARIFICATIONS & SPECIFICATIONS:

1. The bid due date remains as **Wednesday, March 16, 2022 no later than 2:00pm.**
2. The gazebo identified in the Project Manual is a Basis-of-Design product. Equal or equivalent products are allowed as long the size remains 12ft x 16ft and the manufacturer meet the criteria of the manufacturer listed in the Project Manual. The gazebo installation must meet conditions of labor identified in the Project Manual, which is Union Certification or a Collective Bargaining Agreement Certification. Please qualify your bid.
3. Install all new electrical receptacles and wall light and/or fan switches in EVERY room. Color: White. Verify ALL receptacles and switches are in proper/correct working condition.
4. A single wall switch is preferred for all Sleeping Rooms for the ceiling fan/light. Provide pull chains for fan and light.
5. The existing electrical service will need to be brought up to code by addressing the issues with the two main breaker panels. They are currently double tapped at the main.

There are no revised drawings in this Addendum.

End of Addendum No. 2